



Telephone:0484-2925765
email:qcSDLvypin@gmail.com

KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB,VYPIN - 682508

(NABL Recognized Sub Divisional Level Government Drinking Water Testing Laboratory)

WATER TEST REPORT

Report No: KWA/QCSDL-VP/3782/02/25

Report of Issue Date: 22.02.2025

Customer Name &Address	Date of Receipt of Payment	13.02.2025
ST. JOSEPH'S PUBLIC SCHOOL NJARAKKAL	Date of Sample received	14.02.2025
	Sample given by	Customer
	Sample Code	VP/3782/02/25
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Tap Water (Filtered)
	Sample Quantity	2Ltr
	Test performing date :15.02.2025 TO 18.02.2025	

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	0.52
2	pH @ 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	7.50
3	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	7.30
4	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	10.10

Remarks:-

- 1) The result stated above related only to the sample(s) submitted for testing by the customer .
- 2) The samples retain for 15 days from the end date of analysis
- 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory
- 4)BDL-Below Detection Limit
- 5)DL-Detectable Limit

Reviewed & Analysed By

Technical Manager

Remya E R

End of Report

KWA/QCSDL/VP/F-21	Issue Date : 20.09.21	Issue no:01
Rev No:5	Rev.Date :11.11.2024	Page 1of 1





Telephone:0484-2925765
email:-qscdlvypin@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, VYPIN - 682508
WATER TEST REPORT

Report No: KWA/QCSDL-VP/3782/02/25

Report of Issue Date: 22.02.2025

Customer Name &Address	Date of Receipt of Payment	13.02.2025
ST. JOSEPH'S PUBLIC SCHOOL NJARAKKAL	Date of Sample received	14.02.2025
	Sample given by	Customer
	Sample Code	VP/3782/02/25
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Tap Water (Filtered)
	Sample Quantity	2Ltr
	Test performing date :15.02.2025 TO 18.02.2025	

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Nitrate (as NO ₃)	mg/L	IS3025(PART 34/SEC.1)-2023	45	0.43
2	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2024	1	<0.1
3	Electrical conductivity at 25°- C	µS/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)	--	21.00

Remarks:-

- 1) The result stated above related only to the sample(s) submitted for testing by the customer .
- 2) The samples retain for 15 days from the end date of analysis
- 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory
- 4)BDL-Below Detection Limit

Reviewed & Analysed By

Technical Manager
Remya E R

End of Report

KWA/QCSDL/VP/F-21	Issue Date : 20.09.21	Issue no:01
Rev No:5	Rev. Date :11.11.2024	Page 1of 1





Telephone:0484-2925765
email:-qcsdlvypin@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, VYPIN - 682508

WATER TEST REPORT

Report No: KWA/QCSDL-VP/BC3782/02/25

Report of Issue Date: 22.02.2025

Customer Name &Address	Date of Receipt of Payment	13.02.2025		
ST. JOSEPH'S PUBLIC SCHOOL NJARAKKAL	Date of Sample received	14.02.2025		
	Sample given by	Customer		
	Sample Code	VP/BC3782/02/25		
	Sample Name	Drinking Water		
	Sample Condition	Good		
	Source of Sample	Tap Water (Filtered)		
	Sample Quantity	200ml		
Test performing date : 20.02.2025 TO 21.02.2025				
Sl. No.	Source	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be detected/100ml	IS15185-2016	Absent
2	E Coli	Shall not be detected/100ml	IS15185-2016	Absent

Remarks:-

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Reviewed & Analysed By


C V Sreelakshmi

End of Report

KWA/QCSDL/VP/F-21	Issue Date : 20.09.2021	
Rev No: Nil	Rev,Date : Nil	Page 1 of 1

